

SECTION 15423 - CLEANOUTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
 - 1. Cleanouts.

1.3 QUALITY ASSURANCE

- A. For each product specified, provide components by the same manufacturer throughout.

1.4 SUBMITTALS

- A. Submit product data under the provisions of Section 01300. Include component sizes, rough-in requirements, and finishes.

PART 2 - PRODUCTS

2.1 ACCEPTABLE MANUFACTURERS

- A. Cleanouts: Josam, J.R. Smith, or Zurn.

2.2 CLEANOUTS

- A. Interior Finished Floor Areas: Lacquered, cast iron, two piece body with double drainage flange, weep holes, reversible clamping collar, and adjustable nickel-bronze strainer, round with scoriated cover in service areas and round, square cover to accept floor finish in finished floor areas, equal to Zurn Series ZB-1400.

PART 3 - EXECUTION

3.1 INSTALLATION AND APPLICATION

- A. Extend cleanouts to finished floor or wall surface. Lubricate threaded cleanout plugs with mixture of graphite and linseed oil. Ensure clearance at cleanout for rodding of drainage system.

END OF SECTION 15423